

# TYPE CERTIFICATE



Czech

**Registration number 12.690.543**

issued for the manufacturer:

**SINOP CB a.s.  
Jeseniova 2851/32  
CZ - 130 00 Praha 3 - Žižkov  
Company Registration No.: 26028867**

for the product:

Name: **EMPTY ENCLOSURE FOR LOW VOLTAGE CONTROLGEAR**  
 Type designation: **SW š x v x h**  
 Modification: **--**  
 Place of production: **SINOP CB a.s.  
Pod Stromovkou 205, CZ - 370 01 České Budějovice**

at which the certification has been conducted pursuant to ISO/IEC 17067 – scheme 3 certification scheme in accordance with TÜV SÜD Czech certification system. The results are stated in Evaluation report file No. 12.710.400 from 24.10.2019.

The product type mentioned above fulfils the applicable requirements of the following regulations/standards which were the basis for its evaluation:

**ČSN EN 62208 ed.2:2012, ČSN EN 60519 +A1+A2:2014,  
ČSN EN 62262+A1:2000.**

This certificate is valid till: **30.10.2024**

Details and validity conditions are stated in the annex which forms an integral part of this Certificate and contains 1 page.

This certificate is issued on the basis of voluntary certification, and it does not substitute outputs of the authorized or notified body.

Prague, 30.10.2019



Head of the certification body

1. The product specimen was entered for evaluation and type certification on 17.09.2019.
2. The Certificate was issued on the basis of the documents provided by the client:
  - Purchasing order from 17.09.2019
  - Application for certification dated 17.09.2019
  - Technical documentation of the product
3. The assessment of factory production control was performed at the product manufacturer concentrating on elements ensuring the continuation of product conformity with certification requirements.
4. Detailed technical data characterizing the product type:

Type designation:	<b>SW š x v x h</b>
Material:	<b>metal plate of thickness 1,5 mm</b>
Way of fixing:	<b>on the wall or metal structure, on pedestal (floor mounting)</b>
Place of service	<b>indoor / outdoor</b>
Ambient temperature:	<b>- 25°C - + 40°C</b>
IP protection:	<b>IP 43, IP 44, IP 54, IP 56</b>
IK protection:	<b>IK 08</b>
Remark:	<b>š = width, v = height, h = depth (mm)</b>

5. List of important parts of the technical documentation :
  - It is given in the Evaluation report No. 12.710.400 from 24.10.2019.
6. Validity Conditions
  - The certificate shall apply only to its holder and products and production places mentioned therein.
  - The transfer of the certificate by its owner to third parties is inadmissible as well as the use of certificate by third parties.
  - TÜV SÜD Czech shall be notified forthwith of any product modifications compared to the certified specimen. This fact may cause the certificate continuation dependent on an additional conformity evaluation.
  - TÜV SÜD Czech shall supervise the proper functioning of the Quality System at the manufacturer within a period of 1 year on the basis of a concluded contract about the controlling activity.
  - The certificate can be renewed on request.
  - The certificate shall only be reproduced complete including all the annexes.
  - The right to use TÜV SÜD Czech certification mark was not established to the certificate.
  - The certificate holder commits to keep records of all the relevant complaints concerning the conformity of the products with the requirements of regulations and standards and make those records available to the certification body TÜV SÜD Czech.
  - Not specified items (advertising, use of certification mark and certificates) are governed by the General Conditions for Product Certification, as amended.

